



CONSTRUCTION NOTES:

1. The installation of this practice shall be according to NRCS Construction and Material Specifications attached.
2. Concrete mix shall be approved by NRCS prior to pours and mix shall have the following properties:
 - a) 28 day compressive strength greater that 3500 psi
 - b) air entrained
3. Reinforcing steel and aggregate size shall not exceed 1-1/2 inches.
4. Joints in floor shall be spaced 30 feet or less.
5. Provide construction joint between wall and base as shown.
6. Bars should be spliced every 20 feet and staggered. Lap length shall be at least 12 inches.
7. The drawing requires supporting technical documentation prior to use and must be adapted to the specific site.

Drawing not to scale.

Designed _____ Drawn _____ 3/2005 Checked _____ Approved _____	Date _____ CAD FILE NAME OR_10FT_WALL.DWG DRAWING NO. _____ SHEET _____ OF _____	<p>10 FT ABOVE GROUND DRY STACK STORAGE STRUCTURE</p> <p>ANIMAL WASTE</p> <p>NRCS U.S.D.A. NATURAL RESOURCES CONSERVATION SERVICE</p>
--	---	---