

---

CONSTRUCTION SPECIFICATION  
INSTRUCTION FOR USE  
CS-I-OR-045 PLASTIC PIPE

---

045.1 APPLICABILITY

Construction Specification CS-OR-045 is applicable for the use of plastic pipe conduits except corrugated polyethylene tubing (see MS-OR-548, Corrugated Polyethylene Tubing).

045.2 MATERIAL SPECIFICATION

The following material specification complements Construction Specification CS-OR-045:

- a) MS-OR-547—Plastic Pipe

045.3 INCLUDED ITEMS

Items to be included in the construction specification and drawings follow:

- a) Line and grade of the conduit.
- b) Details of the bedding and shape and placement requirements.
- c) Description of the bedding material and grading limits, if needed.
- d) Excavation requirements. Provide necessary information for excavation, minimum trench width, if applicable and any special considerations necessary in case of unstable trench bottom or walls or for safety.
- e) Backfill requirements. Provide necessary information of backfill, compaction requirements, or other special methods of performing and controlling backfill, including the kind of material, as appropriate.
- f) Specify industry (ASTM or AWWA) material standards or specifications that the pipe material is required to meet, as applicable.

The designer may require a specific type of pipe by listing in Section 045.13, Items of Work and Construction Details, of this construction specification or the appropriate reference specification(s). The designer must be prepared to evaluate and accept pipe meeting other references that equal or exceed the minimum specified when proposed by the contractor or supplier. NRCS maintains a limited list of reference specifications in NRCS offices for use of design and construction personnel.

- g) Specify the salient features of the pipe that are required to meet the intent of the design.
  1. Size (diameter, include ID or OD if critical) and type of plastic (PE, HDPE, ABS, PVC 1120, or other).
  2. Schedule, SDR or DR, pressure class, and/ or pressure rating, as appropriate.
  3. Perforation requirements if different from Material Specification MS-OR-547 Plastic Pipe.
- h) Type of joint by referring to a reference specification or details of any specific joint requirements.
- i) Details of special fittings, when applicable.
- j) Type of protective coatings for special fittings and appurtenances, when applicable (include field repair requirements).
- k) Pressure testing specifications, including rate of filling requirements, if applicable. The test pressure specified should not be less than the normal operating pressure together with the duration of the test with the allowable pressure change that is acceptable.
- l) Specify and detail concrete thrust blocks, encasement, and anchors where applicable. Requirements for concrete encasement and for thrust blocks if other than Construction Specification CS-220, Reinforced Concrete, Class 3000M.

#### 045.4 METHODS

The methods are self-explanatory. The choice of method must be consistent with the function of the conduit and the required operating pressure.

#### 045.5 DISCUSSION

This specification is written to include cast iron pipe sizes, iron pipe sizes (IPS), sewer pipe, pressure pipe, water pipe, drainpipe, and plastic irrigation pipe (PIP).

In addition to the ductile iron and cast iron fittings, one piece, injection molded, gasketed PVC plastic fittings are available for PVC pipe. These fitting are available for sewer pipe sizes 4 inches to 15 inches, for IPS-PVC pipe sizes 1.5 inches to 8 inches, and for AWWA Standard C900 pipes that are compatible with cast iron pipe sizes 4 inches to 8 inches.

#### 045.6 ITEMS OF WORK AND CONSTRUCTION DETAILS

Starting at the top of page 045–8, prepare and outline job specific "Items of Work and Construction Details" (IWCD) in accordance with these instructions.