

---

CONSTRUCTION SPECIFICATION  
CS-OR-227 ROCK SURFACING

---

227.1 SCOPE

The work shall consist of furnishing and installing loose rock surfacing at the locations shown on the drawings.

227.2 SITE PREPARATION

The site shall be prepared by removing all vegetative matter to minimum depth of 6 inches from the surface. When specified, a drainage system shall be installed.

227.3 FOUNDATION

The foundation shall be firm and be able to support the design loads without consolidation or yielding. Where the foundation material is to be removed and replaced, the material shall be compacted to the density specified on the drawings.

227.4 INSTALLATION

The rock surfacing shall be of the material, gradation and be installed to the dimensions shown on the drawings.

227.5 ITEMS OF WORK AND CONSTRUCTION DETAILS